

Standards For Fire Pits

Must be made from steel or non-combustible material. Solid structure or if decorative cutouts, they must be screened with 1/8" steel mesh.

Standard pit size—max 36" diameter, between 7 3/8" and 16" high.

Create a 1.5' clearance by removing all combustibles down to mineral soil. Fill cleared area in with gravel or rock. ***Option—dig hole in ground, set pit inside, fill with cement, then create clearance area)*

Create a 10' radius combustible free zone

Create a vertical clearance of 10' by removing overhanging branches

Pit must be 25' from all structures

Pit must be 50' from all logging slash/debris

Pit needs to be maintained (clean out debris after each use)

